Contactors DILM, DILH

## **Ordering** Accessories


## Moeller HPL0211-2007/2008 http://catalog.moeller.net DILM...-XPS, ETS4-VS3 Actuating Rated operational current Actuating Contact sequence Part no. Price Std. For use Article no. pack voltage current with see price list AC-15 DC 240 V 415 V $I_{\mathsf{e}}$ $U_{s}$ Ι $I_{\mathsf{e}}$ $I_{\mathsf{e}}$ Α Α V DC mΑ Amplifier module for separate mounting Input with integrated suppressor for overvoltage limit 25 ETS4-VS3 1 off 24 As required 083094 4



Contactor coils with rated operational current > 2 A must be actuated via the DILA mini contactor relay.

Rated operational current DC:

Making and breaking conditions DC-13, time L/R 300ms



DILM1000-XSP/E(RA250)



274202

274205

DILM1000-XSP/E(RA250)

DILH1400-XSP/E(RAW250)

DILM250-S-XSP/E(220-240V50/60HZ)

DILM500-S-XSP/E(220-240V50/60HZ)

DILM500 DILM580

DILM650 DILM750 DILM820 DILM1000 DILH1400

DILM185-S

DILM225-S

DILM250-S DILM300-S

DILM400-S DILM500-S



<sup>1)</sup> Including electronics module